



IMPORTANT NOTICE:
Earth ground the intrinsically safe module.

Wiring from the ground terminal must be connected to a good earth ground in a non-hazardous location and less than 1 ohm (in accordance with Nation Electrical Code Article 250).

Intrinsically safe wiring must be positively segregated from non-intrinsically safe wiring by separate conduits, housings or by use of grounded metal barriers. For additional information see ANSI/ISA RP12.6, The National Electrical Code and NFPA 70, Articles 500-516.

			Contegra		8160 County Rd 42 W, Suite 300-405, Savage, MN 55378 Phone (651)905-0900, Fax (651)454-4665 www.Contegra.com		Copyright 2014 Contegra Inc.
			Description: ISB-M1d Physical & Connections with SLX 130-MIS				
02	4/23/14	Rotated physical layout to agree w/electrical layout	Designed: MCS		Drawing #: 10461-0001-02 Page 1 of 1		
01	4/9/14	Released	Date: 4/9/14				
Rv	Date	Description					